

Power Analyser UMG 806

Modbus-address list
and Formulary



Content

Address list	4
Data and time	4
Fourier analysis	4
Meter information	8
Measured value (250 ms measuring window)	9
Demand values	11
Maximum Minimum values	13
Frequently required readings	19
System Set	21

Copyright

This handbook is subject to the legal regulations of the copyright laws and may not be fully or partially photocopied, reprinted or reproduced mechanically or electronically and may not be copied or published in any other way without the legal, written permission of

Janitza electronics GmbH
Vor dem Polstück 6
D35633 Lahnau
Germany

Protected trademarks

All trademarks and the resulting rights belong to the respective owners of these rights.

Disclaimer

Janitza electronics GmbH does not accept any responsibility for errors or faults within this handbook and does not accept any obligation to keep the contents of this handbook updated.

Comments on the handbook

We welcome your comments. If anything appears to be unclear in this handbook, please let us know and send us an E-MAIL to: info@janitza.de

Address list

Frequently required readings

Data and time

Address	Format	RD/WR	Designation	Unit	Note
0	long64	RD			
4	int	RD			
6	short	RD	_DAY		Day (1..31)
7	short	RD	_MONTH		Month (0=Jan,..11=Dec)
8	short	RD	_YEAR		Year
9	short	RD	_HOUR	h	Hour (0..24)
10	short	RD	_MIN	min	Minute (0..59)
11	short	RD	_SEC	s	Second (0..59)
12	short	RD	_WEEKDAY		Weekday (0=Sun,..6=Sat)

Fourier analysis

Address	Format	RD/WR	Designation	Unit	Note
13	float	RD	_FFT_UL1[0]	%	U L1 Harmonic 2.
15	float	RD	_FFT_UL1[1]	%	U L1 Harmonic 3.
17	float	RD	_FFT_UL1[2]	%	U L1 Harmonic 4.
19	float	RD	_FFT_UL1[3]	%	U L1 Harmonic 5.
21	float	RD	_FFT_UL1[4]	%	U L1 Harmonic 6.
23	float	RD	_FFT_UL1[5]	%	U L1 Harmonic 7.
25	float	RD	_FFT_UL1[6]	%	U L1 Harmonic 8.
27	float	RD	_FFT_UL1[7]	%	U L1 Harmonic 9.
29	float	RD	_FFT_UL1[8]	%	U L1 Harmonic 10.
31	float	RD	_FFT_UL1[9]	%	U L1 Harmonic 11.
33	float	RD	_FFT_UL1[10]	%	U L1 Harmonic 12.
35	float	RD	_FFT_UL1[11]	%	U L1 Harmonic 13.
37	float	RD	_FFT_UL1[12]	%	U L1 Harmonic 14.
39	float	RD	_FFT_UL1[13]	%	U L1 Harmonic 15.
41	float	RD	_FFT_UL1[14]	%	U L1 Harmonic 16.
43	float	RD	_FFT_UL1[15]	%	U L1 Harmonic 17.
45	float	RD	_FFT_UL1[16]	%	U L1 Harmonic 18.
47	float	RD	_FFT_UL1[17]	%	U L1 Harmonic 19.
49	float	RD	_FFT_UL1[18]	%	U L1 Harmonic 20.
51	float	RD	_FFT_UL1[19]	%	U L1 Harmonic 21.

53	float	RD	_FFT_UL1[20]	%	U L1 Harmonic 22.
55	float	RD	_FFT_UL1[21]	%	U L1 Harmonic 23.
57	float	RD	_FFT_UL1[22]	%	U L1 Harmonic 24.
59	float	RD	_FFT_UL1[23]	%	U L1 Harmonic 25.
61	float	RD	_FFT_UL1[24]	%	U L1 Harmonic 26.
63	float	RD	_FFT_UL1[25]	%	U L1 Harmonic 27.
65	float	RD	_FFT_UL1[26]	%	U L1 Harmonic 28.
67	float	RD	_FFT_UL1[27]	%	U L1 Harmonic 29.
69	float	RD	_FFT_UL1[28]	%	U L1 Harmonic 30.
71	float	RD	_FFT_UL1[29]	%	U L1 Harmonic 31.
73	float	RD	_FFT_UL2[0]	%	U L2 Harmonic 2.
75	float	RD	_FFT_UL2[1]	%	U L2 Harmonic 3.
77	float	RD	_FFT_UL2[2]	%	U L2 Harmonic 4.
79	float	RD	_FFT_UL2[3]	%	U L2 Harmonic 5.
81	float	RD	_FFT_UL2[4]	%	U L2 Harmonic 6.
83	float	RD	_FFT_UL2[5]	%	U L2 Harmonic 7.
85	float	RD	_FFT_UL2[6]	%	U L2 Harmonic 8.
87	float	RD	_FFT_UL2[7]	%	U L2 Harmonic 9.
89	float	RD	_FFT_UL2[8]	%	U L2 Harmonic 10.
91	float	RD	_FFT_UL2[9]	%	U L2 Harmonic 11.
93	float	RD	_FFT_UL2[10]	%	U L2 Harmonic 12.
95	float	RD	_FFT_UL2[11]	%	U L2 Harmonic 13.
97	float	RD	_FFT_UL2[12]	%	U L2 Harmonic 14.
99	float	RD	_FFT_UL2[13]	%	U L2 Harmonic 15.
101	float	RD	_FFT_UL2[14]	%	U L2 Harmonic 16.
103	float	RD	_FFT_UL2[15]	%	U L2 Harmonic 17.
105	float	RD	_FFT_UL2[16]	%	U L2 Harmonic 18.
107	float	RD	_FFT_UL2[17]	%	U L2 Harmonic 19.
109	float	RD	_FFT_UL2[18]	%	U L2 Harmonic 20.
111	float	RD	_FFT_UL2[19]	%	U L2 Harmonic 21.
113	float	RD	_FFT_UL2[20]	%	U L2 Harmonic 22.
115	float	RD	_FFT_UL2[21]	%	U L2 Harmonic 23.
117	float	RD	_FFT_UL2[22]	%	U L2 Harmonic 24.
119	float	RD	_FFT_UL2[23]	%	U L2 Harmonic 25.
121	float	RD	_FFT_UL2[24]	%	U L2 Harmonic 26.
123	float	RD	_FFT_UL2[25]	%	U L2 Harmonic 27.
125	float	RD	_FFT_UL2[26]	%	U L2 Harmonic 28.
127	float	RD	_FFT_UL2[27]	%	U L2 Harmonic 29.
129	float	RD	_FFT_UL2[28]	%	U L2 Harmonic 30.
131	float	RD	_FFT_UL2[29]	%	U L2 Harmonic 31.
133	float	RD	_FFT_UL3[0]	%	U L3 Harmonic 2.

135	float	RD	_FFT_UL3[1]	%	U L3 Harmonic 3.
137	float	RD	_FFT_UL3[2]	%	U L3 Harmonic 4.
139	float	RD	_FFT_UL3[3]	%	U L3 Harmonic 5.
141	float	RD	_FFT_UL3[4]	%	U L3 Harmonic 6.
143	float	RD	_FFT_UL3[5]	%	U L3 Harmonic 7.
145	float	RD	_FFT_UL3[6]	%	U L3 Harmonic 8.
147	float	RD	_FFT_UL3[7]	%	U L3 Harmonic 9.
149	float	RD	_FFT_UL3[8]	%	U L3 Harmonic 10.
151	float	RD	_FFT_UL3[9]	%	U L3 Harmonic 11.
153	float	RD	_FFT_UL3[10]	%	U L3 Harmonic 12.
155	float	RD	_FFT_UL3[11]	%	U L3 Harmonic 13.
157	float	RD	_FFT_UL3[12]	%	U L3 Harmonic 14.
159	float	RD	_FFT_UL3[13]	%	U L3 Harmonic 15.
161	float	RD	_FFT_UL3[14]	%	U L3 Harmonic 16.
163	float	RD	_FFT_UL3[15]	%	U L3 Harmonic 17.
165	float	RD	_FFT_UL3[16]	%	U L3 Harmonic 18.
167	float	RD	_FFT_UL3[17]	%	U L3 Harmonic 19.
169	float	RD	_FFT_UL3[18]	%	U L3 Harmonic 20.
171	float	RD	_FFT_UL3[19]	%	U L3 Harmonic 21.
173	float	RD	_FFT_UL3[20]	%	U L3 Harmonic 22.
175	float	RD	_FFT_UL3[21]	%	U L3 Harmonic 23.
177	float	RD	_FFT_UL3[22]	%	U L3 Harmonic 24.
179	float	RD	_FFT_UL3[23]	%	U L3 Harmonic 25.
181	float	RD	_FFT_UL3[24]	%	U L3 Harmonic 26.
183	float	RD	_FFT_UL3[25]	%	U L3 Harmonic 27.
185	float	RD	_FFT_UL3[26]	%	U L3 Harmonic 28.
187	float	RD	_FFT_UL3[27]	%	U L3 Harmonic 29.
189	float	RD	_FFT_UL3[28]	%	U L3 Harmonic 30.
191	float	RD	_FFT_UL3[29]	%	U L3 Harmonic 31.
193	float	RD	_FFT_IL1[0]	%	I L1 Harmonic 2.
195	float	RD	_FFT_IL1[1]	%	I L1 Harmonic 3.
197	float	RD	_FFT_IL1[2]	%	I L1 Harmonic 4.
199	float	RD	_FFT_IL1[3]	%	I L1 Harmonic 5.
201	float	RD	_FFT_IL1[4]	%	I L1 Harmonic 6.
203	float	RD	_FFT_IL1[5]	%	I L1 Harmonic 7.
205	float	RD	_FFT_IL1[6]	%	I L1 Harmonic 8.
207	float	RD	_FFT_IL1[7]	%	I L1 Harmonic 9.
209	float	RD	_FFT_IL1[8]	%	I L1 Harmonic 10.
211	float	RD	_FFT_IL1[9]	%	I L1 Harmonic 11.
213	float	RD	_FFT_IL1[10]	%	I L1 Harmonic 12.
215	float	RD	_FFT_IL1[11]	%	I L1 Harmonic 13.

217	float	RD	_FFT_IL1[12]	%	I L1 Harmonic 14.
219	float	RD	_FFT_IL1[13]	%	I L1 Harmonic 15.
221	float	RD	_FFT_IL1[14]	%	I L1 Harmonic 16.
223	float	RD	_FFT_IL1[15]	%	I L1 Harmonic 17.
225	float	RD	_FFT_IL1[16]	%	I L1 Harmonic 18.
227	float	RD	_FFT_IL1[17]	%	I L1 Harmonic 19.
229	float	RD	_FFT_IL1[18]	%	I L1 Harmonic 20.
231	float	RD	_FFT_IL1[19]	%	I L1 Harmonic 21.
233	float	RD	_FFT_IL1[20]	%	I L1 Harmonic 22.
235	float	RD	_FFT_IL1[21]	%	I L1 Harmonic 23.
237	float	RD	_FFT_IL1[22]	%	I L1 Harmonic 24.
239	float	RD	_FFT_IL1[23]	%	I L1 Harmonic 25.
241	float	RD	_FFT_IL1[24]	%	I L1 Harmonic 26.
243	float	RD	_FFT_IL1[25]	%	I L1 Harmonic 27.
245	float	RD	_FFT_IL1[26]	%	I L1 Harmonic 28.
247	float	RD	_FFT_IL1[27]	%	I L1 Harmonic 29.
249	float	RD	_FFT_IL1[28]	%	I L1 Harmonic 30.
251	float	RD	_FFT_IL1[29]	%	I L1 Harmonic 31.
253	float	RD	_FFT_IL2[0]	%	I L2 Harmonic 2.
255	float	RD	_FFT_IL2[1]	%	I L2 Harmonic 3.
257	float	RD	_FFT_IL2[2]	%	I L2 Harmonic 4.
259	float	RD	_FFT_IL2[3]	%	I L2 Harmonic 5.
261	float	RD	_FFT_IL2[4]	%	I L2 Harmonic 6.
263	float	RD	_FFT_IL2[5]	%	I L2 Harmonic 7.
265	float	RD	_FFT_IL2[6]	%	I L2 Harmonic 8.
267	float	RD	_FFT_IL2[7]	%	I L2 Harmonic 9.
269	float	RD	_FFT_IL2[8]	%	I L2 Harmonic 10.
271	float	RD	_FFT_IL2[9]	%	I L2 Harmonic 11.
273	float	RD	_FFT_IL2[10]	%	I L2 Harmonic 12.
275	float	RD	_FFT_IL2[11]	%	I L2 Harmonic 13.
277	float	RD	_FFT_IL2[12]	%	I L2 Harmonic 14.
279	float	RD	_FFT_IL2[13]	%	I L2 Harmonic 15.
281	float	RD	_FFT_IL2[14]	%	I L2 Harmonic 16.
283	float	RD	_FFT_IL2[15]	%	I L2 Harmonic 17.
285	float	RD	_FFT_IL2[16]	%	I L2 Harmonic 18.
287	float	RD	_FFT_IL2[17]	%	I L2 Harmonic 19.
289	float	RD	_FFT_IL2[18]	%	I L2 Harmonic 20.
291	float	RD	_FFT_IL2[19]	%	I L2 Harmonic 21.
293	float	RD	_FFT_IL2[20]	%	I L2 Harmonic 22.
295	float	RD	_FFT_IL2[21]	%	I L2 Harmonic 23.
297	float	RD	_FFT_IL2[22]	%	I L2 Harmonic 24.

299	float	RD	_FFT_IL2[23]	%	I L2 Harmonic 25.
301	float	RD	_FFT_IL2[24]	%	I L2 Harmonic 26.
303	float	RD	_FFT_IL2[25]	%	I L2 Harmonic 27.
305	float	RD	_FFT_IL2[26]	%	I L2 Harmonic 28.
307	float	RD	_FFT_IL2[27]	%	I L2 Harmonic 29.
309	float	RD	_FFT_IL2[28]	%	I L2 Harmonic 30.
311	float	RD	_FFT_IL2[29]	%	I L2 Harmonic 31.
313	float	RD	_FFT_IL3[0]	%	I L3 Harmonic 2.
315	float	RD	_FFT_IL3[1]	%	I L3 Harmonic 3.
317	float	RD	_FFT_IL3[2]	%	I L3 Harmonic 4.
319	float	RD	_FFT_IL3[3]	%	I L3 Harmonic 5.
321	float	RD	_FFT_IL3[4]	%	I L3 Harmonic 6.
323	float	RD	_FFT_IL3[5]	%	I L3 Harmonic 7.
325	float	RD	_FFT_IL3[6]	%	I L3 Harmonic 8.
327	float	RD	_FFT_IL3[7]	%	I L3 Harmonic 9.
329	float	RD	_FFT_IL3[8]	%	I L3 Harmonic 10.
331	float	RD	_FFT_IL3[9]	%	I L3 Harmonic 11.
333	float	RD	_FFT_IL3[10]	%	I L3 Harmonic 12.
335	float	RD	_FFT_IL3[11]	%	I L3 Harmonic 13.
337	float	RD	_FFT_IL3[12]	%	I L3 Harmonic 14.
339	float	RD	_FFT_IL3[13]	%	I L3 Harmonic 15.
341	float	RD	_FFT_IL3[14]	%	I L3 Harmonic 16.
343	float	RD	_FFT_IL3[15]	%	I L3 Harmonic 17.
345	float	RD	_FFT_IL3[16]	%	I L3 Harmonic 18.
347	float	RD	_FFT_IL3[17]	%	I L3 Harmonic 19.
349	float	RD	_FFT_IL3[18]	%	I L3 Harmonic 20.
351	float	RD	_FFT_IL3[19]	%	I L3 Harmonic 21.
353	float	RD	_FFT_IL3[20]	%	I L3 Harmonic 22.
355	float	RD	_FFT_IL3[21]	%	I L3 Harmonic 23.
357	float	RD	_FFT_IL3[22]	%	I L3 Harmonic 24.
359	float	RD	_FFT_IL3[23]	%	I L3 Harmonic 25.
361	float	RD	_FFT_IL3[24]	%	I L3 Harmonic 26.
363	float	RD	_FFT_IL3[25]	%	I L3 Harmonic 27.
365	float	RD	_FFT_IL3[26]	%	I L3 Harmonic 28.
367	float	RD	_FFT_IL3[27]	%	I L3 Harmonic 29.
369	float	RD	_FFT_IL3[28]	%	I L3 Harmonic 30.
371	float	RD	_FFT_IL3[29]	%	I L3 Harmonic 31.

Meter information

Address	Format	RD/WR	Designation	Note
911	long	RD	Meter Serial Num	
913	short	RD	Firmware Version	

Measured value (250 ms measuring window)

Address	Format	RD/WR	Designation	Unit	Note
2029	float	RD	_THD_ULN[0]	%	Harmonic, THD, UL1-N
2031	float	RD	_THD_ULN[1]	%	Harmonic, THD, UL2-N
2033	float	RD	_THD_ULN[2]	%	Harmonic, THD, UL3-N
2035	float	RD			
2037	float	RD	_THD_IL[0]	%	Harmonic, THD, IL1-N
2039	float	RD	_THD_IL[1]	%	Harmonic, THD, IL2-N
2041	float	RD	_THD_IL[2]	%	Harmonic, THD, IL3-N
2043	float	RD			
2045	float	RD	_KFACT[0]		K-Factor, L
2047	float	RD	_KFACT[1]		K-Factor, L
2049	float	RD	_KFACT[2]		K-Factor, L
2051	float	RD			
2053	float	RD	_ULN[0]	V	Voltage L1_N
2053	float	RD	_ULN[1]	V	Voltage L2_N
2057	float	RD	_ULN[2]	V	Voltage L3_N
2059	float	RD			
2061	float	RD	_ILN[0]	A	Apparent current, L1
2063	float	RD	_ILN[1]	A	Apparent current, L2
2065	float	RD	_ILN[2]	A	Apparent current, L3
2067	float	RD	_IN	A	Apparent current, IN
2069	float	RD	_PLN[0]	kW	Real Power L1
2071	float	RD	_PLN[1]	kW	Real Power L2
2073	float	RD	_PLN[2]	kW	Real Power L3
2075	float	RD			
2077	float	RD	_QLN[0]	kvar	Reactive Power L1
2079	float	RD	_QLN[1]	kvar	Reactive Power L2
2081	float	RD	_QLN[2]	kvar	Reactive Power L3
2083	float	RD			
2085	float	RD	_SLN[0]	kVA	Apparent power, L1
2087	float	RD	_SLN[1]	kVA	Apparent power, L2
2089	float	RD	_SLN[2]	kVA	Apparent power, L3
2091	float	RD			
2093	float	RD	_ULL[0]	V	Phase conductor, UL1-L2
2095	float	RD	_ULL[1]	V	Phase conductor, UL2-L3
2097	float	RD	_ULL[2]	V	Phase conductor, UL3-L1
2099	float	RD	_I_SUM3	A	Vector sum, IN=I1+I2+I3

2101	float	RD			
2103	float	RD	_S_SUM3	kVA	Sum, $S=S1+S2+S3$
2105	float	RD	_P_SUM3	kW	Sum, $P=P1+P2+P3$
2107	float	RD	_Q_SUM3	kvar	Mains frequency reactive power, sum, $Q=Q1+Q2+Q3$
2109	float	RD			
2111 - 2150	Reserve				
2151	float	RD	_PHASE[0]	°	Phase, UL1 IL1
2153	float	RD	_PHASE[1]	°	Phase, UL2 IL2
2155	float	RD	_PHASE[2]	°	Phase, UL3 IL3
2157	float	RD			
2159	float	RD	_COS_PHI[0]		Fund.power factor, CosPhi; UL1 IL1
2161	float	RD	_COS_PHI[1]		Fund.power factor, CosPhi; UL2 IL2
2163	float	RD	_COS_PHI[2]		Fund.power factor, CosPhi; UL3 IL3
2165	float	RD			
2167	float	RD	_IND_CAP[0]		Sign,QL1, +1=ind.,-1=cap.
2169	float	RD	_IND_CAP[1]		Sign,QL1, +1=ind.,-1=cap.
2171	float	RD	_IND_CAP[2]		Sign,QL1, +1=ind.,-1=cap.
2173	float	RD			
2175	float	RD	_FREQ	Hz	Measured frequency
2177	float	RD	_UN	V	Zero sequence, voltage
2179	float	RD	_UM	V	Positive sequence, voltage
2181	float	RD	_UG	V	Negative sequence, voltage
2183	float	RD	_U_SYM	%	Unsymmetrical; voltage
2185	float	RD			
2187	float	RD	_IN	A	Zero sequence, current
2189	float	RD	_IM	A	Positive sequence, current
2191	float	RD	_IG	A	Negative sequence, current
2193	float	RD	_I_SYM	%	Unsymmetrical; current

Demand values

Address	Format	RD/WR	Designation	Unit	Note
4215	float	RD	_PreDemand[0]	The unit is related to the setting data type, and the data unit in Measure Values has been	Demand data of last cycle
4217	float	RD	_PreDemand[1]		
4219	float	RD	_PreDemand[2]		
4221	float	RD	_PreDemand[3]		
4223	float	RD	_PreDemand[4]		
4225	float	RD	_PreDemand[5]		
4227	float	RD	_PreDemand[6]		
4229	float	RD	_PreDemand[7]		
4231	float	RD	_PreDemand[8]		
4233	float	RD	_NowDemand[0]	The unit is related to the setting data type, and the data unit in Measure Values has been	Demand data of present cycle
4235	float	RD	_NowDemand[1]		
4237	float	RD	_NowDemand[2]		
4239	float	RD	_NowDemand[3]		
4241	float	RD	_NowDemand[4]		
4243	float	RD	_NowDemand[5]		
4245	float	RD	_NowDemand[6]		
4247	float	RD	_NowDemand[7]		
4249	float	RD	_NowDemand[8]		
4251	float	RD	_MaxDemand[0]	The unit is related to the setting data type, and the data unit in Measure Values has been	Max. demand of history
4253	float	RD	_MaxDemand[1]		
4255	float	RD	_MaxDemand[2]		
4257	float	RD	_MaxDemand[3]		
4259	float	RD	_MaxDemand[4]		
4261	float	RD	_MaxDemand[5]		
4263	float	RD	_MaxDemand[6]		
4265	float	RD	_MaxDemand[7]		
4267	float	RD	_MaxDemand[8]		
4269	char	RD	_Time_MaxDemand[0]	Demand Max Time	High Byte: Year Low Byte: Month
4270	char	RD			High Byte: Day Low Byte: Hour
4271	char	RD			High Byte: Minute Low Byte: Second
4272	char	RD	_Time_MaxDemand[1]	Demand Max Time	High Byte: Year Low Byte: Month
4273	char	RD			High Byte: Day Low Byte: Hour
4274	char	RD			High Byte: Minute Low Byte: Second

4275	char	RD	_Time_MaxDemand[2]	Demand Max Time	High Byte: Year Low Byte: Month
4276	char	RD			High Byte: Day Low Byte: Hour
4277	char	RD			High Byte: Minute Low Byte: Second
4278	char	RD	_Time_MaxDemand[3]	Demand Max Time	High Byte: Year Low Byte: Month
4279	char	RD			High Byte: Day Low Byte: Hour
4280	char	RD			High Byte: Minute Low Byte: Second
4281	char	RD	_Time_MaxDemand[4]	Demand Max Time	High Byte: Year Low Byte: Month
4282	char	RD			High Byte: Day Low Byte: Hour
4283	char	RD			High Byte: Minute Low Byte: Second
4284	char	RD	_Time_MaxDemand[5]	Demand Max Time	High Byte: Year Low Byte: Month
4285	char	RD			High Byte: Day Low Byte: Hour
4286	char	RD			High Byte: Minute Low Byte: Second
4287	char	RD	_Time_MaxDemand[6]	Demand Max Time	High Byte: Year Low Byte: Month
4288	char	RD			High Byte: Day Low Byte: Hour
4289	char	RD			High Byte: Minute Low Byte: Second
4290	char	RD	_Time_MaxDemand[7]	Demand Max Time	High Byte: Year Low Byte: Month
4291	char	RD			High Byte: Day Low Byte: Hour
4292	char	RD			High Byte: Minute Low Byte: Second
4293	char	RD	_Time_MaxDemand[8]	Demand Max Time	High Byte: Year Low Byte: Month
4294	char	RD			High Byte: Day Low Byte: Hour
4295	char	RD			High Byte: Minute Low Byte: Second

Maximum Minimum values

Address	Format	RD/WR	Designation	Unit	Note
6397	float	RD	_ULN_MAX[0]	V	Maximum, UL1-N
6399	float	RD	_ULN_MAX[1]	V	Maximum, UL2-N
6401	float	RD	_ULN_MAX[2]	V	Maximum, UL3-N
6403	float	RD	_ULL_MAX[0]	V	Maximum, UL1-L2
6405	float	RD	_ULL_MAX[1]	V	Maximum, UL2-L3
6407	float	RD	_ULL_MAX[2]	V	Maximum, UL3-L1
6409	float	RD	_ILN_MAX[0]	A	Maximum, I L1
6411	float	RD	_ILN_MAX[1]	A	Maximum, I L2
6413	float	RD	_ILN_MAX[2]	A	Maximum, I L3
6415	float	RD	_ILN_MAX[3]	A	Maximum, IN=I1+I2+I3
6417	float	RD	_P_SUM3_MAX	kW	Maximum, Psum3=P1+P2+P3
6419	float	RD	_Q_SUM3_MAX	kvar	Maximum, Qsum3=Q1+Q2+Q3
6421	float	RD	_S_SUM3_MAX	kVA	Maximum, Ssum3=S1+S2+S3
6423	float	RD	_PF_SUM3_MAX		Maximum, Psum3/Ssum3
6425	float	RD	_FREQ_MAX	Hz	Maximum, frequency
6427	float	RD	_ULN_MIN[0]	V	Minimum, UL1-N
6429	float	RD	_ULN_MIN[1]	V	Minimum, UL2-N
6431	float	RD	_ULN_MIN[2]	V	Minimum, UL3-N
6433	float	RD	_ULL_MIN[0]	V	Minimum, UL1-L2
6435	float	RD	_ULL_MIN[1]	V	Minimum, UL2-L3
6437	float	RD	_ULL_MIN[2]	V	Minimum, UL3-L1
6439	float	RD	_ILN_MIN[0]	A	Minimum, I L1
6441	float	RD	_ILN_MIN[1]	A	Minimum, I L2
6443	float	RD	_ILN_MIN[2]	A	Minimum, I L3
6445	float	RD	_ILN_MIN[3]	A	Minimum, IN=I1+I2+I3
6447	float	RD	_P_SUM3_MIN	kW	Minimum, Psum3=P1+P2+P3
6449	float	RD	_Q_SUM3_MIN	kvar	Minimum, Qsum3=Q1+Q2+Q3
6451	float	RD	_S_SUM3_MIN	kVA	Minimum, Ssum3=S1+S2+S3
6453	float	RD	_PF_SUM3_MIN		Minimum, Psum3/Ssum3
6455	float	RD	_FREQ_MIN	Hz	Minimum, frequency
6457	char	RD	_Time_ULN_MAX[0]		High Byte: Year Low Byte: Month
6458	char	RD			High Byte: Day Low Byte: Hour
6459	char	RD			High Byte: Minute Low Byte: Second

6460	char	RD	_Time_ULN_MAX[1]	High Byte: Year Low Byte: Month
6461	char	RD		High Byte: Day Low Byte: Hour
6462	char	RD		High Byte: Minute Low Byte: Second
6463	char	RD	_Time_ULN_MAX[2]	High Byte: Year Low Byte: Month
6464	char	RD		High Byte: Day Low Byte: Hour
6465	char	RD		High Byte: Minute Low Byte: Second
6466	char	RD	_Time_ULL_MAX[0]	High Byte: Year Low Byte: Month
6467	char	RD		High Byte: Day Low Byte: Hour
6468	char	RD		High Byte: Minute Low Byte: Second
6469	char	RD	_Time_ULL_MAX[1]	High Byte: Year Low Byte: Month
6470	char	RD		High Byte: Day Low Byte: Hour
6471	char	RD		High Byte: Minute Low Byte: Second
6472	char	RD	_Time_ULL_MAX[2]	High Byte: Year Low Byte: Month
6473	char	RD		High Byte: Day Low Byte: Hour
6474	char	RD		High Byte: Minute Low Byte: Second
6475	char	RD	_Time_ILN_MAX[0]	High Byte: Year Low Byte: Month
6476	char	RD		High Byte: Day Low Byte: Hour
6477	char	RD		High Byte: Minute Low Byte: Second
6478	char	RD	_Time_ILN_MAX[1]	High Byte: Year Low Byte: Month
6479	char	RD		High Byte: Day Low Byte: Hour
6480	char	RD		High Byte: Minute Low Byte: Second
6481	char	RD	_Time_ILN_MAX[2]	High Byte: Year Low Byte: Month
6482	char	RD		High Byte: Day Low Byte: Hour
6483	char	RD		High Byte: Minute Low Byte: Second
6484	char	RD	_Time_ILN_MAX[3]	High Byte: Year Low Byte: Month
6485	char	RD		High Byte: Day Low Byte: Hour
6486	char	RD		High Byte: Minute Low Byte: Second

6487	char	RD	_Time_P_SUM3_MAX	High Byte: Year Low Byte: Month
6488	char	RD		High Byte: Day Low Byte: Hour
6489	char	RD		High Byte: Minute Low Byte: Second
6490	char	RD	_Time_Q_SUM3_MAX	High Byte: Year Low Byte: Month
6491	char	RD		High Byte: Day Low Byte: Hour
6492	char	RD		High Byte: Minute Low Byte: Second
6493	char	RD	_Time_S_SUM3_MAX	High Byte: Year Low Byte: Month
6494	char	RD		High Byte: Day Low Byte: Hour
6495	char	RD		High Byte: Minute Low Byte: Second
6496	char	RD	_Time_PF_SUM_MAX	High Byte: Year Low Byte: Month
6497	char	RD		High Byte: Day Low Byte: Hour
6498	char	RD		High Byte: Minute Low Byte: Second
6499	char	RD	_Time_FREQ_MAX	High Byte: Year Low Byte: Month
6500	char	RD		High Byte: Day Low Byte: Hour
6501	char	RD		High Byte: Minute Low Byte: Second
6502	char	RD	_Time_ULN_MAX[0]	High Byte: Year Low Byte: Month
6503	char	RD		High Byte: Day Low Byte: Hour
6504	char	RD		High Byte: Minute Low Byte: Second
6505	char	RD	_Time_ULN_MAX[1]	High Byte: Year Low Byte: Month
6506	char	RD		High Byte: Day Low Byte: Hour
6507	char	RD		High Byte: Minute Low Byte: Second
6508	char	RD	_Time_ULN_MAX[2]	High Byte: Year Low Byte: Month
6509	char	RD		High Byte: Day Low Byte: Hour
6510	char	RD		High Byte: Minute Low Byte: Second
6511	char	RD	_Time_ULL_MAX[0]	High Byte: Year Low Byte: Month
6512	char	RD		High Byte: Day Low Byte: Hour
6513	char	RD		High Byte: Minute Low Byte: Second

6514	char	RD	_Time_ULL_MAX[1]	High Byte: Year Low Byte: Month
6515	char	RD		High Byte: Day Low Byte: Hour
6516	char	RD		High Byte: Minute Low Byte: Second
6517	char	RD	_Time_ULL_MAX[2]	High Byte: Year Low Byte: Month
6518	char	RD		High Byte: Day Low Byte: Hour
6519	char	RD		High Byte: Minute Low Byte: Second
6520	char	RD	_Time_ILN_MAX[0]	High Byte: Year Low Byte: Month
6521	char	RD		High Byte: Day Low Byte: Hour
6522	char	RD		High Byte: Minute Low Byte: Second
6523	char	RD	_Time_ILN_MAX[1]	High Byte: Year Low Byte: Month
6524	char	RD		High Byte: Day Low Byte: Hour
6525	char	RD		High Byte: Minute Low Byte: Second
6526	char	RD	_Time_ILN_MAX[2]	High Byte: Year Low Byte: Month
6527	char	RD		High Byte: Day Low Byte: Hour
6528	char	RD		High Byte: Minute Low Byte: Second
6529	char	RD	_Time_ILN_MAX[3]	High Byte: Year Low Byte: Month
6530	char	RD		High Byte: Day Low Byte: Hour
6531	char	RD		High Byte: Minute Low Byte: Second
6532	char	RD	_Time_P_SUM3_MAX	High Byte: Year Low Byte: Month
6533	char	RD		High Byte: Day Low Byte: Hour
6534	char	RD		High Byte: Minute Low Byte: Second
6535	char	RD	_Time_Q_SUM3_MAX	High Byte: Year Low Byte: Month
6536	char	RD		High Byte: Day Low Byte: Hour
6537	char	RD		High Byte: Minute Low Byte: Second
6538	char	RD	_Time_S_SUM3_MAX	High Byte: Year Low Byte: Month
6539	char	RD		High Byte: Day Low Byte: Hour
6540	char	RD		High Byte: Minute Low Byte: Second

6541	char	RD	_Time_PF_SUM_MAX	High Byte: Year Low Byte: Month
6542	char	RD		High Byte: Day Low Byte: Hour
6543	char	RD		High Byte: Minute Low Byte: Second
6544	char	RD	_Time_FREQ_MAX	High Byte: Year Low Byte: Month
6545	char	RD		High Byte: Day Low Byte: Hour
6546	char	RD		High Byte: Minute Low Byte: Second
6547	char	RD	_Time_ULN_MIN[0]	High Byte: Year Low Byte: Month
6548	char	RD		High Byte: Day Low Byte: Hour
6549	char	RD		High Byte: Minute Low Byte: Second
6550	char	RD	_Time_ULN_MIN[1]	High Byte: Year Low Byte: Month
6551	char	RD		High Byte: Day Low Byte: Hour
6552	char	RD		High Byte: Minute Low Byte: Second
6553	char	RD	_Time_ULN_MIN[2]	High Byte: Year Low Byte: Month
6554	char	RD		High Byte: Day Low Byte: Hour
6555	char	RD		High Byte: Minute Low Byte: Second
6556	char	RD	_Time_ULL_MIN[0]	High Byte: Year Low Byte: Month
6557	char	RD		High Byte: Day Low Byte: Hour
6558	char	RD		High Byte: Minute Low Byte: Second
6559	char	RD	_Time_ULL_MIN[1]	High Byte: Year Low Byte: Month
6560	char	RD		High Byte: Day Low Byte: Hour
6561	char	RD		High Byte: Minute Low Byte: Second
6562	char	RD	_Time_ULL_MIN[2]	High Byte: Year Low Byte: Month
6563	char	RD		High Byte: Day Low Byte: Hour
6564	char	RD		High Byte: Minute Low Byte: Second
6565	char	RD	_Time_ILN_MIN[0]	High Byte: Year Low Byte: Month
6566	char	RD		High Byte: Day Low Byte: Hour
6567	char	RD		High Byte: Minute Low Byte: Second

6568	char	RD	_Time_ILN_MIN[1]	High Byte: Year Low Byte: Month
6569	char	RD		High Byte: Day Low Byte: Hour
6570	char	RD		High Byte: Minute Low Byte: Second
6571	char	RD	_Time_ILN_MIN[2]	High Byte: Year Low Byte: Month
6572	char	RD		High Byte: Day Low Byte: Hour
6573	char	RD		High Byte: Minute Low Byte: Second
6574	char	RD	_Time_ILN_MIN[3]	High Byte: Year Low Byte: Month
6575	char	RD		High Byte: Day Low Byte: Hour
6576	char	RD		High Byte: Minute Low Byte: Second
6577	char	RD	_Time_P_SUM3_MIN	High Byte: Year Low Byte: Month
6578	char	RD		High Byte: Day Low Byte: Hour
6579	char	RD		High Byte: Minute Low Byte: Second
6580	char	RD	_Time_Q_SUM3_MIN	High Byte: Year Low Byte: Month
6581	char	RD		High Byte: Day Low Byte: Hour
6582	char	RD		High Byte: Minute Low Byte: Second
6583	char	RD	_Time_S_SUM3_MIN	High Byte: Year Low Byte: Month
6584	char	RD		High Byte: Day Low Byte: Hour
6585	char	RD		High Byte: Minute Low Byte: Second
6586	char	RD	_Time_PF_SUM_MIN	High Byte: Year Low Byte: Month
6587	char	RD		High Byte: Day Low Byte: Hour
6588	char	RD		High Byte: Minute Low Byte: Second
6589	char	RD	_Time_FREQ_MIN	High Byte: Year Low Byte: Month
6590	char	RD		High Byte: Day Low Byte: Hour
6591	char	RD		High Byte: Minute Low Byte: Second

Frequently required readings

Address	Format	RD/WR	Designation	Unit	Note
19000	float	RD	_G_ULN[0]	V	Voltage L1-N
19002	float	RD	_G_ULN[1]	V	Voltage L2-N
19004	float	RD	_G_ULN[2]	V	Voltage L3-N
19006	float	RD	_G_ULL[0]	V	Voltage L1_L2
19008	float	RD	_G_ULL[1]	V	Voltage L2_L3
19010	float	RD	_G_ULL[2]	V	Voltage L3_L1
19012	float	RD	_G_ILN[0]	A	Apparent current, L1-N
19014	float	RD	_G_ILN[1]	A	Apparent current, L2-N
19016	float	RD	_G_ILN[2]	A	Apparent current, L3-N
19018	float	RD	_G_IN	A	Apparent current, IN
19020	float	RD	_G_PLN[0]	kW	Real power L1-N
19022	float	RD	_G_PLN[1]	kW	Real power L2-N
19024	float	RD	_G_PLN[2]	kW	Real power L3-N
19026	float	RD	_G_P_SUM3	kW	Psum3=P1+P2+P3
19028	float	RD	_G_SLN[0]	kVA	Apparent power L1-N
19030	float	RD	_G_SLN[1]	kVA	Apparent power L2-N
19032	float	RD	_G_SLN[2]	kVA	Apparent power L3-N
19034	float	RD	_G_S_SUM3	kVA	Sum;Ssum=S1+S2+S3
19036	float	RD	_G_QLN[0]	kvar	Reactive power L1 (fundamental comp.)
19038	float	RD	_G_QLN[1]	kvar	Reactive power L2 (fundamental comp.)
19040	float	RD	_G_QLN[2]	kvar	Reactive power L3 (fundamental comp.)
19042	float	RD	_G_Q_SUM3	kvar	Qsum3=Q1+Q2+Q3
19044	float	RD	_G_COS_PH[0]	-	CosPhi; UL1 IL1 (fundamental comp.)
19046	float	RD	_G_COS_PH[1]	-	CosPhi; UL1 IL2 (fundamental comp.)
19048	float	RD	_G_COS_PH[2]	-	CosPhi; UL1 IL3 (fundamental comp.)
19050	float	RD	_G_FREQ	Hz	Measure frequency
19052	float	RD			
19054	float	RD	_G_WH[0]	kWh	Real energy L1
19056	float	RD	_G_WH[1]	kWh	Real energy L2
19058	float	RD	_G_WH[2]	kWh	Real energy L3
19060	float	RD	_G_WH_SUML13	kWh	Real energy L1..L3
19062	float	RD	_G_WH_V[0]	kWh	Real energy L1, consumed
19064	float	RD	_G_WH_V[1]	kWh	Real energy L2, consumed
19066	float	RD	_G_WH_V[2]	kWh	Real energy L3, consumed
19068	float	RD	_G_V_HT_SUML13	kWh	Real energy L1..L3, consumed
19070	float	RD	_G_WH_Z[0]	kWh	Real energy L1, delivered

19072	float	RD	_G_WH_Z[1]	kWh	Real energy L2, delivered
19074	float	RD	_G_WH_Z[2]	kWh	Real energy L3, delivered
19076	float	RD	_G_WH_Z_SUML3	kWh	Real energy L1...L3, delivered
19078	float	RD	_G_WH_S[0]	kVAh	Apparent energy L1
19080	float	RD	_G_WH_S[1]	kVAh	Apparent energy L2
19082	float	RD	_G_WH_S[2]	kVAh	Apparent energy L3
19084	float	RD	_G_WH_S_SUML3	kVAh	Apparent energy L1...L3
19086	float	RD	_G_QH[0]	kvarh	Reactive energy L1 (fundamental comp.)
19088	float	RD	_G_QH[1]	kvarh	Reactive energy L2 (fundamental comp.)
19090	float	RD	_G_QH[2]	kvarh	Reactive energy L3 (fundamental comp.)
19092	float	RD	_G_QH_SUML3	kvarh	Reactive energy L4 (fundamental comp.)
19094	float	RD	_G_IQH[0]	kvarh	Reactive energy, inductive L1 (fundamental comp.)
19096	float	RD	_G_IQH[1]	kvarh	Reactive energy, inductive L2 (fundamental comp.)
19098	float	RD	_G_IQH[2]	kvarh	Reactive energy, inductive L3 (fundamental comp.)
19100	float	RD	_G_IQH_SUML3	kvarh	Reactive energy, inductive L1..L3 (fundamental comp.)
19102	float	RD	_G_CQH[0]	kvarh	Reactive energy, capacitive L1 (fundamental comp.)
19104	float	RD	_G_CQH[1]	kvarh	Reactive energy, capacitive L2 (fundamental comp.)
19106	float	RD	_G_CQH[2]	kvarh	Reactive energy, capacitive L3 (fundamental comp.)
19108	float	RD	_G_CQH_SUML3	kvarh	Reactive energy, capacitive L4 (fundamental comp.)
19110	float	RD	_G_THD_ULN[0]	%	Harmonic,THD, U L1-N
19112	float	RD	_G_THD_ULN[1]	%	Harmonic,THD, U L2-N
19114	float	RD	_G_THD_ULN[2]	%	Harmonic,THD, U L3-N
19116	float	RD	_G_THD_ILN[0]	%	Harmonic,THD, I L1
19118	float	RD	_G_THD_ILN[1]	%	Harmonic,THD, I L2
19120	float	RD	_G_THD_ILN[2]	%	Harmonic,THD, I L3
19122	float	RD	_G_PT100	°C	UMG806 PT100
19124	float	RD	_G_I5	mA	UMG806 I5 inputs
19126	float	RD	_E1_I_[0]	mA	E1 Module current inputs
19128	float	RD	_E1_I_[1]	mA	E1 Module current inputs
19130	float	RD	_E1_I_[2]	mA	E1 Module current inputs
19132	float	RD	_E1_I_[3]	mA	E1 Module current inputs

19134	Int	RD	_DO_OUTPUT		Bit0: EI1_DO1 Bit1: EI1_DO2 Bit2: EK1_DO1 Bit3: EK1_DO2 0: Off 1:ON
19135	Int	RD	_DI_INPUT		Bit0: EK1_DI1 Bit1: EK1_DI2 Bit2: EK1_DI3 Bit3: EK1_DI4 0: Off 1: ON

System Set

Address	Format	RD/WR	Designation 1	Designation 2
30000	short	RD/WR	Main body: Slave address	1-247
30001	short	RD/WR	Main body: Baud rate	0: 1200bps 1: 2400bps 2: 4800bps 3: 9600bps 4: 19200bps 5: 38400bps
30002	short	RD/WR	Main body: Data format	0: N,8,1 1: E,8,1 2: O,8,1 3: N,8,2
30003				
30004	short	RD/WR	Wiring	0: 3P4W 1: 3P3W 2: 1P2W
30005	short	RD/WR	Grid frequency	0: 50Hz 1: 60Hz
30006	short	RD	Current type1	0: 5A 1:Direct type
30007	short	RD	Current type2	0: Solid-core CT 1 Split-core CT
30008	Long	RD/WR	PT primary	1~999999V
30010	Long	RD/WR	CT primary	1~999999A
30012	short	RD/WR	PT secondary	1~690V
30013	short	RD/WR	CT secondary	1~6A
30014	short	RD/WR	nCT	1-9999
30015				
30016	short	RD/WR	Demand1 item	0:Ua, 1:Ub, 2:Uc 3:Uab, 4:Ubc, 5:Uca 6:la, 7:lb, 8:lc, 9:ln, 10:Pa, 11:Pb, 12:Pc, 13:P, 14:Qa, 15:Qb, 16:Qc, 17:Q, 18:Sa, 19:S2, 20:S3, 21:S, 22:PFa, 23:PFb, 24:PFc, 25:PF

30017	short	RD/WR	Demand2 item	The Same to Demand1 Item
30018	short	RD/WR	Demand3 item	The Same to Demand1 Item
30019	short	RD/WR	Demand4 item	The Same to Demand1 Item
30020	short	RD/WR	Demand5 item	The Same to Demand1 Item
30021	short	RD/WR	Demand6 item	The Same to Demand1 Item
30022	short	RD/WR	Demand7 item	The Same to Demand1 Item
30023	short	RD/WR	Demand8 item	The Same to Demand1 Item
30024	short	RD/WR	Demand9 item	The Same to Demand1 Item
30025	short	RD/WR	Mode of demand	0: sliding block mode 1: fixed block mode
30026	short	RD/WR	Sliding time(t)	1-9999s
30027	short	RD/WR	Demand period(T)	(1-30)xt
30028	short	RD/WR	Relay output E11-DO1 mode	0: OFF 1: alarm 2: remote control
30029	short	RD/WR	Relay output E11-DO1 Pulse width	0.1~99.99s 0.0: no pulse
30030	short	RD/WR	Relay output E11-DO1 Item	0: V1 > 1: V1 < 2: V2 > 3: V2 < 4: V3 > 5: V3 < 6: Vn > 7: Vn < 8: V12 > 9: V12 < 10: V23 > 11: V23 < 12: V31 > 13: V31 < 14: V1 > 15: V1 < 16: Vlnavg > 17: Vlnavg < 18: Vllavg > 19: Vllavg < 20: I1 > 21: I1 < 22: I2 > 23: I2 < 24: I3 > 25: I3 < 26: I > 27: I < 24: Iavg > 29: Iavg < 30: In > 31: In < 32: P > 33: P < 34: Q > 35: Q < 36: S > 37: S < 38: PF > 39: PF < 40: F > 41: F < 42: Uunb > 43: Uunb < 44: Iunb > 45: Iunb < 46: THDu > 47: THDu < 48: THDi > 49: THDi < 50: Alarm State 1 51: Alarm State 0 52: DIX_1 53: DIX_0 54: DI1_1 55: DI1_0 56: DI2_1 57: DI2_0 58: DI3_1, 59: DI3_0, 60: DI4_1 61: DI4_0I
30031	short			
30032	short			

30033	short	RD/WR	Relay outputs E11-DO1 Delay Time	0.1~99.99s
30034	short	RD/WR	Relay output E11-DO2 mode	0: OFF 1: alarm 2: remote control
30035	short	RD/WR	Relay output E11-DO2 Pulse width	
30036	short	RD/WR	Relay output E11-DO2 Item	
30037				
30038				
30039	short		Relay outputs E11-DO2 Delay Time	0.1~99.99s
30040	short	RD/WR	Relay output ED1-DO1 mode	0: OFF 1: alarm 2: remote control
30041	short	RD/WR	Relay output ED1-DO1 Pulse width	
30042	short	RD/WR	Relay output ED1-DO1 Item	Same above
30043				
30044				
30045	short	RD/WR	Relay outputs ED1-DO1 Delay Time	0.1~99.99s
30046	short	RD/WR	Relay output EK1-DO2 mode	0: OFF 1: alarm 2: remote control
30047	short	RD/WR	Relay output EK1-DO2 Pulse width	0.1~99.99s
30048	short	RD/WR	Relay output EK1-DO2 Item	Same above
30049				
30050				
30051	short	RD/WR	Relay outputs ED1-DO2 Delay Time	0.1~99.99s
30052	float	RD/WR	E11_DO1 Alarm Value	
30054	float	RD/WR	E11_DO1 Alarm Hys	
30056	float	RD/WR	E11_DO2 Alarm Value	
30058	float	RD/WR	E11_DO2 Alarm Hys	
30060	float	RD/WR	EK1_DO1 Alarm Value	
30062	float	RD/WR	EK1_DO1 Alarm Hys	
30064	float	RD/WR	EK1_DO2 Alarm Value	
30066	float	RD/WR	EK1_DO2 Alarm Hys	

30068	float	RD/WR	Un Alarm High Value	V
30070	float	RD/WR	Un Alarm High Hys	V
30072	float	RD/WR	Un Alarm Low Value	V
30074	float	RD/WR	Un Alarm Low Hys	V
30076	float	RD/WR	Un Alarm Time Dealy	s
30078	float	RD/WR	UI Alarm High Value	V
30080	float	RD/WR	UI Alarm High Hys	V
30082	float	RD/WR	UI Alarm Low Value	V
30084	float	RD/WR	UI Alarm Low Hys	V
30086	float	RD/WR	UI Alarm Time Dealy	s
30088	float	RD/WR	In Alarm High Value	A
30090	float	RD/WR	In Alarm High Hys	A
30092	float	RD/WR	In Alarm Low Value	A
30094	float	RD/WR	In Alarm Low Hys	A
30096	float	RD/WR	In Alarm Time Dealy	s
30098	float	RD/WR	F Alarm High Value	Hz
30100	float	RD/WR	F Alarm High Hys	Hz
30102	float	RD/WR	F Alarm Low Value	Hz
30104	float	RD/WR	F Alarm Low Hys	Hz
30106	float	RD/WR	In Alarm Time Dealy	s
30108	float	RD/WR	Pall Alarm High Value	kW
30110	float	RD/WR	Pall Alarm High Hys	kW
30112	float	RD/WR	Pall Alarm Low Value	kW
30114	float	RD/WR	Pall Alarm Low Hys	kW
30116	float	RD/WR	Pall Alarm Time Dealy	s
30118	float	RD/WR	PF Alarm High Value	
30120	float	RD/WR	PF Alarm High Hys	
30122	float	RD/WR	PF Alarm Time Dealy	s
30124	float	RD/WR	THDU Alarm High Value	%
30126	float	RD/WR	THDU Alarm High Hys	%
30128	float	RD/WR	THDU Alarm Time Dealy	s
30130	float	RD/WR	THDI Alarm High Value	%
30132	float	RD/WR	THDI Alarm High Hys	%
30134	float	RD/WR	THDI Alarm Time Dealy	s
30136	float	RD/WR	U_SYM Alarm High Value	
30138	float	RD/WR	U_SYM Alarm High Hys	
30140	float	RD/WR	U_SYM Alarm Time Dealy	s
30142	float	RD/WR	I_SYM Alarm High Value	
30144	float	RD/WR	I_SYM Alarm High Hys	
30146	float	RD/WR	I_SYM Alarm Time Dealy	s

30148	short	RD/WR	Alarm Enable: 1: enable 0: close Bit0: phase voltage high alarm enable Bit1: phase voltage low alarm enable Bit2: line voltage high alarm enable Bit3: line voltage low alarm enable Bit4: current high alarm enable Bit5: current low alarm enable Bit6: Frequency high alarm enable Bit7: Frequency low alarm enable Bit8: Totalactiveharminic high alarm enable Bit9: Totalactiveharminic low alarm enable Bit10: Total reactive high alarm enable Bit11: Total reactive low alarm enable Bit12: Total apparent power high alarm enable Bit13: Total apparent power low alarm enable Bit14: Total power factor low alarm enable Bit15: THDv high alarm enable	
30149	short	RD/WR	Bit0: THDi high alarm enable Bit1: Voltage unbalance high alarm enable Bit2: Current unbalance low alarmenable Bit3-Bit15: Reserved	
30150	short	RD/WR	TCP/IP Port	
30151-30152	char	RD/WR	IP[4]	
30153-30154	char	RD/WR	Mask[4]	
30155-30156	char	RD/WR	Gate[4]	
30157-30159	reserve			
30160	short	RD/WR	Max. Min. Period Time	0: History Max. Min. Value !0: Zone Max. Min. Value 0-9999 min.

optec

energie ist messbar

Optec AG | Guyer-Zeller-Strasse 14 | CH-8620 Wetzikon ZH

Telefon: +41 44 933 07 70 | Telefax: +41 44 933 07 77

E-Mail: info@optec.ch | Internet: www.optec.ch

Janitza®

Janitza electronics GmbH
Vor dem Polstück 6
35633 Lahnau, Germany

Tel.: +49 6441 - 9642-0
E-mail: info@janitza.de
info@janitza.de | www.janitza.de

Subject to technical changes.

The most current status of the document can be found in the download area at www.janitza.de.